

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

平成31年4月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	月	8:40	9.7					7.4	1.2	
2	火	8:38	9.8	42	68	9.7	0.04	7.4	1.8	37.3
3	水	8:38	9.7					7.5	1.8	
4	木	8:36	9.7					7.6	1.5	
5	金	8:37	9.6					7.5	1.1	
6	土									
7	日									
8	月	8:39	10.4					7.5	1.1	
9	火	8:39	11.9	42	79	10	0.12	7.4	2.3	37.3
10	水	8:41	11.1					7.4	1.3	
11	木	8:38	10.6					7.4	2.7	
12	金	8:39	9.4					7.4	1.2	
13	土									
14	日									
15	月	8:37	11.4					7.5	1.6	
16	火	8:37	11.0	39	66	9.7	0.03	7.4	1.3	35.2
17	水	9:14	11.1					7.5	1.1	
18	木	8:36	11.2					7.5	1.2	
19	金	8:37	11.0					7.3	1.1	
20	土									
21	日									
22	月	8:40	11.9					7.4	1.4	
23	火	8:39	13.1	40	69	9.6	<0.03	7.6	1.2	35.8
24	水	8:38	12.6					7.4	1.3	
25	木	9:48	12.7					7.4	1.4	
26	金	8:39	13.1					7.5	1.4	
27	土									
28	日									
29	月									
30	火									
-	-									
平均	—		11.1	41	71	9.8	0.05	7.5	1.5	36.4
最高	—		13.1	42	79	10	0.12	7.6	2.7	37.3
最低	—		9.4	39	66	9.6	<0.03	7.3	1.1	35.2
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和1年5月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	水									
2	木									
3	金									
4	土									
5	日									
6	月									
7	火	8:41	15.5					8.0	4.1	
8	水	8:37	13.6	38	63	9.8	<0.03	7.5	2.1	34.3
9	木	8:36	14.9					7.7	2.8	
10	金	8:38	14.4					7.5	1.9	
11	土									
12	日									
13	月	8:37	14.9					7.7	2.2	
14	火	8:37	16.5	39	69	9.9	<0.03	8.3	3.2	35.5
15	水	8:38	15.6					8.1	2.4	
16	木	8:36	15.4					8.2	2.5	
17	金	8:38	15.7					8.2	2.2	
18	土									
19	日									
20	月	8:39	14.7					7.4	1.5	
21	火	8:37	14.5	38	65	9.5	<0.03	7.4	1.4	34.0
22	水	8:38	15.9					7.7	1.7	
23	木	8:37	16.2					7.6	1.9	
24	金	8:38	16.6					7.6	2.0	
25	土									
26	日									
27	月	8:38	17.5					7.9	1.9	
28	火	8:38	19.5	38	67	9.6	<0.03	7.6	1.9	34.8
29	水	8:37	19.0					7.5	1.9	
30	木	8:37	18.6					7.5	1.5	
31	金	8:38	17.9					7.3	1.8	
平均		—	16.2	38	66	9.7	<0.03	7.7	2.2	34.7
最高		—	19.5	39	69	9.9	<0.03	8.3	4.1	35.5
最低		—	13.6	38	63	9.5	<0.03	7.3	1.4	34.0
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和1年6月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	土									
2	日									
3	月	8:37	19.5					7.8	1.7	
4	火	8:38	19.1	38	72	9.9	<0.03	7.6	1.9	35.9
5	水	8:36	19.0					7.9	1.9	
6	木	8:37	19.9					8.1	2.1	
7	金	8:40	19.5					8.0	2.3	
8	土									
9	日									
10	月	8:42	20.4					7.3	2.2	
11	火	8:39	19.3	36	78	9.7	<0.03	7.5	1.7	34.6
12	水	8:39	19.5					7.5	1.6	
13	木	8:38	20.0					7.8	1.8	
14	金	8:36	19.9					7.5	1.7	
15	土									
16	日									
17	月	8:39	19.3					7.6	2.7	
18	火	8:38	19.7	37	76	9.6	<0.03	7.8	1.6	34.9
19	水	8:37	19.8					8.0	1.2	
20	木	8:36	20.0					8.0	1.8	
21	金	8:37	20.2					8.0	1.7	
22	土									
23	日									
24	月	8:39	22.6					7.6	1.5	
25	火	8:37	21.3	37	73	9.8	<0.03	7.4	1.5	34.8
26	水	8:36	22.2					7.9	1.2	
27	木	8:37	22.2					8.1	1.2	
28	金	8:37	22.8					7.8	1.2	
29	土									
30	日									
-	-									
平均	—		20.3	37	75	9.8	<0.03	7.8	1.7	35.1
最高	—		22.8	38	78	9.9	<0.03	8.1	2.7	35.9
最低	—		19.0	36	72	9.6	<0.03	7.3	1.2	34.6
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和1年7月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	月	8:38	22.5					7.7	1.1	
2	火	8:44	23.0	43	73	9.9	<0.03	7.7	1.2	
3	水	8:37	23.1					7.6	1.5	
4	木	8:37	23.0					7.6	1.4	
5	金	8:40	23.6					7.6	1.6	
6	土									
7	日									
8	月	8:40	23.9					7.5	1.6	
9	火	8:37	23.6	43	74	9.6	<0.03	7.4	1.2	36.9
10	水	8:38	23.7					7.8	1.0	
11	木	8:37	23.4					7.5	1.0	
12	金	8:37	23.2					7.5	1.2	
13	土									
14	日									
15	月									
16	火	8:37	23.7					7.7	1.3	
17	水	8:38	23.8	46	82	9.9	0.04	7.6	1.4	39.5
18	木	8:39	24.2					7.8	1.0	
19	金	8:42	23.8					7.2	1.9	
20	土									
21	日									
22	月	8:40	24.5					7.9	1.4	
23	火	8:40	24.5	40	66	9.3	<0.03	7.9	0.7	35.1
24	水	8:39	24.4					7.8	3.1	
25	木	8:37	24.7					7.8	2.0	
26	金	8:37	26.2					7.8	0.9	
27	土									
28	日									
29	月	8:37	24.9	42	76	8.3	0.12	7.6	5.5	36.3
30	火	8:37	25.6					7.7	3.2	
31	水	8:36	27.0					7.9	1.5	
平均		—	24.1	43	74	9.4	0.03	7.7	1.7	37.0
最高		—	27.0	46	82	9.9	0.12	7.9	5.5	39.5
最低		—	22.5	40	66	8.3	<0.03	7.2	0.7	35.1
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和1年8月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	木	9:53	28.0					7.8	2.0	
2	金	8:37	26.8					7.8	1.3	
3	土									
4	日									
5	月	8:42	29.5					7.6	1.4	
6	火	8:36	28.6	41	72	9.3	0.03	7.5	1.6	38.4
7	水	8:39	28.5					7.8	1.5	
8	木	8:38	28.8					7.8	1.3	
9	金	8:37	29.2					7.8	1.4	
10	土									
11	日									
12	月									
13	火									
14	水									
15	木									
16	金	8:37	23.9					7.4	35	
17	土									
18	日									
19	月	8:39	27.4					7.4	2.1	
20	火	8:48	27.6	41	71	9.0	0.05	7.2	2.4	38.2
21	水	8:38	27.5					7.1	1.8	
22	木	8:38	27.2					7.2	2.6	
23	金	8:39	28.1					7.5	1.3	
24	土									
25	日									
26	月	8:38	27.7					7.6	1.5	
27	火	9:51	27.5	44	80	9.1	0.04	7.4	1.7	41.2
28	水	8:39	27.3					7.5	1.1	
29	木	8:38	26.9					7.4	1.0	
30	金	8:36	26.6					7.3	1.1	
31	土									
平均	—		27.6	42	74	9.1	0.04	7.5	3.5	39.3
最高	—		29.5	44	80	9.3	0.05	7.8	35	41.2
最低	—		23.9	41	71	9.0	0.03	7.1	1.0	38.2
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和1年9月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	日									
2	月	8:37	26.5					7.4	1.1	
3	火	8:37	26.6	42	77	9.2	<0.03	7.4	1.0	38.0
4	水	8:45	26.7					7.4	1.0	
5	木	8:38	26.4					7.1	1.1	
6	金	8:38	27.0					7.5	0.9	
7	土									
8	日									
9	月	8:38	27.9					7.4	1.0	
10	火	8:36	27.7	40	76	9.3	<0.03	7.2	1.3	35.7
11	水	8:36	28.0					7.5	1.1	
12	木	8:37	28.0					7.4	2.9	
13	金	8:37	27.3					7.3	2.5	
14	土									
15	日									
16	月									
17	火	8:38	26.4					7.3	3.0	
18	水	8:57	26.3	40	75	9.9	0.03	7.3	3.3	39.7
19	木	8:37	24.9					7.3	5.5	
20	金	8:38	24.8					7.3	2.6	
21	土									
22	日									
23	月									
24	火	8:40	24.1					7.3	1.5	
25	水	8:39	23.9	42	65	9.2	<0.03	7.4	1.6	37.0
26	木	8:40	24.1					7.4	1.5	
27	金	8:45	24.0					7.2	1.2	
28	土									
29	日									
30	月	8:38	24.7					7.3	1.1	
-	-									
平均		—	26.1	41	73	9.4	<0.03	7.3	1.9	37.6
最高		—	28.0	42	77	9.9	0.03	7.5	5.5	39.7
最低		—	23.9	40	65	9.2	<0.03	7.1	0.9	35.7
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和1年10月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	火	8:49	24.5	39	65	9.1	<0.03	7.3	1.0	35.2
2	水	8:41	24.8					7.4	1.1	
3	木	8:37	24.3					7.1	1.5	
4	金	8:36	24.0					7.3	0.9	
5	土									
6	日									
7	月	8:37	23.1					7.4	1.7	
8	火	8:39	23.4	39	72	9.8	<0.03	7.5	1.7	36.7
9	水	8:33	22.1					7.3	2.6	
10	木	8:36	21.6					7.4	1.7	
11	金	8:37	23.0					7.4	1.2	
12	土									
13	日									
14	月									
15	火	8:40	20.6					7.3	4.0	
16	水	8:37	19.8	43	70	9.2	0.04	7.4	2.4	38.8
17	木	8:39	20.1					7.4	1.5	
18	金	8:36	20.3					7.4	1.6	
19	土									
20	日									
21	月	8:38	20.1					7.4	1.9	
22	火									
23	水	8:39	19.9	40	69	8.8	0.04	7.3	2.8	36.4
24	木	8:38	20.2					7.3	1.7	
25	金	8:39	19.8					7.3	1.8	
26	土									
27	日									
28	月	8:37	19.3					7.5	2.3	
29	火	8:37	19.3	39	63	9.0	<0.03	7.6	1.6	37.7
30	水	8:36	18.9					7.6	1.5	
31	木	8:36	19.1					7.5	1.1	
平均	—	—	21.3	40	68	9.2	<0.03	7.4	1.8	37.0
最高	—	—	24.8	43	72	9.8	0.04	7.6	4.0	38.8
最低	—	—	18.9	39	63	8.8	<0.03	7.1	0.9	35.2
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和1年11月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	金	8:39	19.0					7.7	1.6	
2	土									
3	日									
4	月									
5	火	8:38	17.3					7.9	2.4	
6	水	8:37	17.4	42	71	9.1	<0.03	7.9	2.0	39.0
7	木	8:36	17.6					8.1	1.9	
8	金	8:38	17.5					8.0	2.6	
9	土									
10	日									
11	月	8:39	16.9					8.0	1.4	
12	火	8:37	16.8	39	71	9.1	<0.03	8.0	1.4	35.5
13	水	8:41	16.3					8.0	1.5	
14	木	8:38	17.1					7.8	1.2	
15	金	8:37	15.7					7.6	2.4	
16	土									
17	日									
18	月	8:38	16.1					7.8	0.9	
19	火	8:40	16.0	41	70	9.1	<0.03	7.7	1.9	37.2
20	水	8:39	15.0					7.7	1.7	
21	木	8:39	14.6					7.7	1.6	
22	金	8:40	14.9					7.8	0.9	
23	土									
24	日									
25	月	8:36	15.5					7.8	1.0	
26	火	8:42	14.7	40	64	9.7	0.03	7.7	2.8	36.8
27	水	8:36	14.7					7.8	2.1	
28	木	8:38	14.5					7.7	4.2	
29	金	8:38	12.9					7.6	1.7	
30	土									
-	-									
平均	—		16.0	41	69	9.3	<0.03	7.8	1.9	37.1
最高	—		19.0	42	71	9.7	0.03	8.1	4.2	39.0
最低	—		12.9	39	64	9.1	<0.03	7.6	0.9	35.5
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和1年12月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	日									
2	月	8:43	13.3					7.7	0.9	
3	火	8:38	13.2	38	68	9.4	<0.03	7.6	1.2	35.4
4	水	8:37	12.5					7.6	1.1	
5	木	8:38	12.4					7.6	1.2	
6	金	8:37	12.2					7.6	1.0	
7	土									
8	日									
9	月	8:39	12.0					7.6	0.8	
10	火	8:37	12.2	40	66	9.1	<0.03	7.7	0.7	35.1
11	水	8:38	12.3					7.6	0.6	
12	木	8:37	12.3					7.7	0.8	
13	金	8:38	11.6					7.6	1.3	
14	土									
15	日									
16	月	8:45	11.1					7.6	1.0	
17	火	8:51	11.7	38	64	9.2	<0.03	7.6	0.7	35.2
18	水	9:19	11.8					7.5	0.8	
19	木	9:33	11.3					7.5	1.1	
20	金	9:21	11.3					7.6	0.8	
21	土									
22	日									
23	月	8:39	11.0					7.5	0.5	
24	火	8:37	11.3	38	60	9.2	<0.03	7.5	0.6	34.7
25	水	8:37	10.9					7.5	0.6	
26	木	8:37	11.1					7.5	0.7	
27	金	8:36	11.0					7.6	1.5	
28	土									
29	日									
30	月									
31	火									
平均	—		11.8	39	65	9.2	<0.03	7.6	0.9	35.1
最高	—		13.3	40	68	9.4	<0.03	7.7	1.5	35.4
最低	—		10.9	38	60	9.1	<0.03	7.5	0.5	34.7
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年1月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	水									
2	木									
3	金									
4	土									
5	日									
6	月	13:46	9.1					7.6	1.7	
7	火	8:36	9.1	43	67	10	0.04	7.6	1.5	37.4
8	水	8:37	9.6					7.5	0.8	
9	木	8:37	9.7					7.5	1.7	
10	金	8:41	9.8					7.6	1.2	
11	土									
12	日									
13	月									
14	火	8:41	9.5					7.6	0.9	
15	水	8:37	9.6	39	71	9.2	<0.03	7.5	0.6	35.2
16	木	8:39	9.2					7.6	0.7	
17	金	8:42	9.1					7.6	0.6	
18	土									
19	日									
20	月	8:39	9.2					7.6	0.9	
21	火	8:39	8.9	41	69	9.4	<0.03	7.6	0.8	36.6
22	水	8:39	8.4					7.6	1.4	
23	木	8:39	8.9					7.6	0.7	
24	金	8:37	9.1					7.6	0.6	
25	土									
26	日									
27	月	8:38	9.4					7.6	0.9	
28	火	8:27	9.1	40	70	9.7	<0.03	7.6	0.8	35.5
29	水	8:40	9.2					7.6	0.7	
30	木	8:39	9.2					7.5	0.7	
31	金	8:38	9.3					7.6	1.9	
平均	—	—	9.2	41	69	9.6	<0.03	7.6	1.0	36.2
最高	—	—	9.8	43	71	10	0.04	7.6	1.9	37.4
最低	—	—	8.4	39	67	9.2	<0.03	7.5	0.6	35.2
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年2月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	土									
2	日									
3	月	8:37	9.0					7.5	0.6	
4	火	8:39	9.0	39	66	9.1	<0.03	7.5	0.6	34.8
5	水	8:38	8.9					7.6	0.6	
6	木	8:39	8.2					7.6	2.2	
7	金	8:39	7.6					7.6	1.4	
8	土									
9	日									
10	月	8:38	7.6					7.6	1.2	
11	火									
12	水	8:38	7.3					7.6	1.3	
13	木	8:40	8.5	38	61	9.9	<0.03	7.4	0.5	34.0
14	金	8:40	8.6					7.4	0.6	
15	土									
16	日									
17	月	8:38	9.2					7.5	0.9	
18	火	8:38	8.5	41	75	9.4	0.07	7.5	4.1	36.4
19	水	8:39	7.9					7.5	5.0	
20	木	8:38	8.7					7.5	1.2	
21	金	8:38	8.6					7.6	1.0	
22	土									
23	日									
24	月									
25	火	8:39	8.8					7.6	1.1	
26	水	8:39	8.9	38	60	9.3	<0.03	7.6	0.9	35.1
27	木	8:37	8.9					7.6	1.4	
28	金	8:40	8.3					7.5	0.8	
29	土									
平均		—	8.5	39	66	9.4	<0.03	7.5	1.4	35.1
最高		—	9.2	41	75	9.9	0.07	7.6	5.0	36.4
最低		—	7.3	38	60	9.1	<0.03	7.4	0.5	34.0
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年3月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	日									
2	月	8:39	8.9					7.7	1.0	
3	火	8:38	9.3	41	67	9.6	0.03	7.6	1.0	36.6
4	水	8:39	9.6					7.7	1.1	
5	木	8:37	9.3					7.7	2.2	
6	金	8:37	8.4					7.6	3.0	
7	土									
8	日									
9	月	8:39	8.9					7.7	1.0	
10	火	8:38	9.0	41	71	9.7	0.04	7.6	1.0	36.9
11	水	8:38	9.5					7.7	1.4	
12	木	8:36	9.9					7.6	5.2	
13	金	8:38	9.4					7.6	0.7	
14	土									
15	日									
16	月	8:41	9.6					7.7	0.8	
17	火	8:36	9.3	49	78	10	0.07	7.7	1.8	43.0
18	水	8:37	9.5					7.4	1.4	
19	木	10:21	9.5					7.8	1.0	
20	金									
21	土									
22	日									
23	月	8:36	10.6					7.7	0.6	
24	火	8:39	10.8	43	74	9.5	0.03	7.6	0.6	36.7
25	水	8:41	9.2					7.5	0.3	
26	木	8:38	9.3					7.4	0.3	
27	金	8:41	10.5					7.6	0.4	
28	土									
29	日									
30	月	8:39	10.1	39	72	9.3	<0.03	7.5	0.4	34.4
31	火	8:39	10.1					7.5	0.3	
平均		—	9.6	43	72	9.6	0.03	7.6	1.2	37.5
最高		—	10.8	49	78	10	0.07	7.8	5.2	43.0
最低		—	8.4	39	67	9.3	<0.03	7.4	0.3	34.4
記事										