

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年4月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	木	8:38	11.5					7.6	0.9	
2	金	8:37	11.8					7.6	0.9	
3	土									
4	日									
5	月	8:40	11.9					7.4	1.3	
6	火	8:39	11.5	40	65	9.3	<0.03	7.4	1.7	34.8
7	水	8:36	12.1					7.3	1.3	
8	木	8:41	11.6					7.4	0.7	
9	金	8:40	12.7					7.4	0.9	
10	土									
11	日									
12	月	8:40	11.6					7.2	1.2	
13	火	8:39	12.0	39	62	9.1	<0.03	7.3	0.8	34.5
14	水	8:39	12.3					7.3	0.9	
15	木	8:39	11.9					7.4	1.1	
16	金	8:39	12.0					7.4	0.8	
17	土									
18	日									
19	月	8:43	11.8					7.4	4.4	
20	火	8:39	11.8	38	64	9.1	<0.03	7.3	1.1	33.9
21	水	8:38	12.1					7.3	1.3	
22	木	8:38	12.8					7.3	0.9	
23	金	11:25	13.5					7.3	1.1	
24	土									
25	日									
26	月	8:42	14.1					7.5	2.4	
27	火	8:44	13.9	43	74	9.5	<0.03	7.4	5.7	37.7
28	水	8:39	14.3					7.5	1.5	
29	木									
30	金	8:38	13.9					7.3	0.9	
-	-									
平均	—		12.4	40	66	9.3	<0.03	7.4	1.5	35.2
最高	—		14.3	43	74	9.5	<0.03	7.6	5.7	37.7
最低	—		11.5	38	62	9.1	<0.03	7.2	0.7	33.9
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年5月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分								
1	土									
2	日									
3	月									
4	火									
5	水									
6	木	8:42	14.3	39	70	9.1	<0.03	7.2	4.2	34.3
7	金	8:42	14.2					7.1	2.6	
8	土									
9	日									
10	月	8:38	14.1					7.2	1.0	
11	火	8:46	14.1	38	64	8.9	<0.03	7.2	0.8	33.4
12	水	8:39	15.2					7.4	1.1	
13	木	8:38	15.8					7.6	1.1	
14	金	8:40	15.5					7.3	0.9	
15	土									
16	日									
17	月	8:42	16.4					7.3	0.8	
18	火	8:40	17.3	38	63	8.9	<0.03	7.4	0.8	33.2
19	水	8:41	17.1					7.4	1.3	
20	木	8:39	16.1					7.4	0.9	
21	金	8:38	16.6					7.3	0.9	
22	土									
23	日									
24	月	8:38	16.7					7.3	2.9	
25	火	8:39	17.8	40	71	8.7	0.04	7.7	2.2	34.9
26	水	8:38	18.0					7.8	1.8	
27	木	8:39	17.0					7.6	1.1	
28	金	8:35	17.4					7.7	2.1	
29	土									
30	日									
31	月	8:40	18.6					8.2	1.5	
平均	—		16.2	39	67	8.9	<0.03	7.5	1.6	34.0
最高	—		18.6	40	71	9.1	0.04	8.2	4.2	34.9
最低	—		14.1	38	63	8.7	<0.03	7.1	0.8	33.2
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年6月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	火	8:42	18.7	37	63	8.8	<0.03	8.3	1.2	33.4
2	水	8:39	19.2					8.4	1.5	
3	木	8:43	19.5					8.8	1.1	
4	金	8:41	19.5					8.2	1.3	
5	土									
6	日									
7	月	8:40	19.4					8.5	1.1	
8	火	8:40	19.8	42	70	8.9	<0.03	8.3	1.5	37.8
9	水	8:41	19.6					8.3	1.5	
10	木	8:39	19.4					8.8	1.4	
11	金	9:31	21.2					8.9	0.8	
12	土									
13	日									
14	月	8:39	21.5					8.8	1.2	
15	火	8:40	21.2	38	66	9.1	<0.03	8.8	1.4	35.0
16	水	10:41	22.5					8.8	1.6	
17	木	8:41	21.2					9.1	1.0	
18	金	8:38	21.0					8.7	1.5	
19	土									
20	日									
21	月	8:40	22.0					8.6	1.3	
22	火	8:40	21.6	38	63	8.7	<0.03	8.8	0.9	34.2
23	水	8:38	22.3					8.7	1.0	
24	木	8:40	22.9					8.7	0.9	
25	金	8:40	22.7					8.4	0.9	
26	土									
27	日									
28	月	8:43	23.3					8.7	0.9	
29	火	8:43	23.1	39	71	8.7	<0.03	8.6	1.0	35.4
30	水	8:38	23.1					8.6	1.2	
-	-									
平均		—	21.1	39	67	8.8	<0.03	8.6	1.2	35.2
最高		—	23.3	42	71	9.1	<0.03	9.1	1.6	37.8
最低		—	18.7	37	63	8.7	<0.03	8.2	0.8	33.4
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年7月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	木	8:45	23.7					8.7	0.9	
2	金	8:42	23.7					8.6	1.1	
3	土									
4	日									
5	月	8:42	24.1					8.2	1.8	
6	火	8:42	24.2	39	73	8.7	<0.03	8.4	1.6	35.0
7	水	8:38	24.5					8.6	1.4	
8	木	8:40	24.4					8.7	0.9	
9	金	8:47	24.5					8.7	0.8	
10	土									
11	日									
12	月	8:42	24.8					7.8	1.2	
13	火	8:42	25.0	41	74	8.6	<0.03	8.2	1.1	37.4
14	水	8:37	25.1					8.5	1.1	
15	木	8:44	25.1					8.0	1.0	
16	金	8:40	25.3					8.4	1.2	
17	土									
18	日									
19	月	8:42	25.5					8.3	0.8	
20	火	8:42	26.2	39	64	8.8	<0.03	8.6	0.8	35.0
21	水	8:41	27.1					8.7	0.7	
22	木									
23	金									
24	土									
25	日									
26	月	8:41	27.0					7.7	1.0	
27	火	8:39	29.0	41	73	9.7	<0.03	8.3	1.1	35.9
28	水	8:39	28.3					8.2	0.9	
29	木	8:43	28.0					8.2	0.8	
30	金	8:41	28.2					8.5	0.6	
31	土									
平均		—	25.7	40	71	9.0	<0.03	8.4	1.0	35.8
最高		—	29.0	41	74	9.7	<0.03	8.7	1.8	37.4
最低		—	23.7	39	64	8.6	<0.03	7.7	0.6	35.0
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年8月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分								
1	日									
2	月	8:42	28.3					7.9	0.9	
3	火	8:41	28.6	38	74	8.7	<0.03	8.4	0.7	34.2
4	水	8:44	28.3					8.3	0.7	
5	木	8:43	28.3					8.3	0.7	
6	金	8:40	28.7					8.4	0.6	
7	土									
8	日									
9	月									
10	火	8:46	24.6					7.3	1.1	
11	水									
12	木									
13	金									
14	土									
15	日									
16	月	8:47	25.0					7.2	2.7	
17	火	8:46	24.9	37	71	8.5	<0.03	7.3	1.7	33.4
18	水	8:42	24.8					7.2	1.9	
19	木	8:41	25.0					7.6	1.4	
20	金	8:39	24.8					7.6	1.0	
21	土									
22	日									
23	月	8:40	24.5					7.2	2.4	
24	火	8:40	25.0	39	70	8.3	<0.03	7.4	1.5	34.9
25	水	8:40	25.3					7.5	1.4	
26	木	8:39	26.0					7.8	0.9	
27	金	8:40	25.9					7.4	1.4	
28	土									
29	日									
30	月	8:42	25.9					7.6	1.4	
31	火	8:39	27.5					7.7	1.2	
平均		—	26.2	38	72	8.5	<0.03	7.7	1.3	34.2
最高		—	28.7	39	74	8.7	<0.03	8.4	2.7	34.9
最低		—	24.5	37	70	8.3	<0.03	7.2	0.6	33.4
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年9月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	水	8:41	26.9	38	63	8.4	<0.03	7.6	0.9	33.3
2	木	8:38	26.9					7.5	1.2	
3	金	8:54	26.4					7.5	1.1	
4	土									
5	日									
6	月	8:40	25.8					7.4	1.5	
7	火	8:39	26.0	38	65	8.4	<0.03	7.5	1.3	33.7
8	水	8:41	25.8					7.3	1.8	
9	木	8:39	25.0					7.4	1.3	
10	金	8:40	25.2					7.5	1.1	
11	土									
12	日									
13	月	8:41	25.0					7.5	0.9	
14	火	8:39	24.7	38	63	8.3	<0.03	7.5	1.1	34.7
15	水	8:39	24.6					7.5	1.0	
16	木	8:53	24.7					7.4	1.4	
17	金	8:42	24.7					7.5	1.2	
18	土									
19	日									
20	月									
21	火	8:41	24.5	38	69	8.4	<0.03	7.5	1.0	34.5
22	水	8:45	24.5					7.3	1.1	
23	木									
24	金	8:41	24.9					7.5	1.3	
25	土									
26	日									
27	月	8:40	23.8					7.3	1.3	
28	火	8:44	24.0	38	66	8.4	<0.03	7.4	1.0	34.2
29	水	8:41	24.1					7.4	0.9	
30	木	8:39	24.2					7.4	0.9	
-	-									
平均	—		25.1	38	65	8.4	<0.03	7.4	1.2	34.1
最高	—		26.9	38	69	8.4	<0.03	7.6	1.8	34.7
最低	—		23.8	38	63	8.3	<0.03	7.3	0.9	33.3
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年10月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分								
1	金	8:41	24.3					7.5	0.9	
2	土									
3	日									
4	月	8:42	23.8					7.4	1.5	
5	火	8:42	23.6	38	64	8.4	<0.03	7.3	1.0	34.0
6	水	8:46	23.9					7.5	1.1	
7	木	8:42	23.8					7.5	1.2	
8	金	8:41	23.8					7.4	1.0	
9	土									
10	日									
11	月	8:43	23.6					7.3	1.1	
12	火	8:42	24.2	37	64	8.4	<0.03	7.6	0.8	33.5
13	水	8:41	24.1					7.5	0.9	
14	木	8:40	23.7					7.5	1.2	
15	金	8:39	23.5					7.6	1.4	
16	土									
17	日									
18	月	8:42	20.7					7.5	4.2	
19	火	8:42	21.2	38	65	8.6	<0.03	7.6	0.9	34.8
20	水	8:47	20.6					7.5	2.1	
21	木	8:42	19.6					7.4	1.6	
22	金	8:40	19.2					7.5	1.2	
23	土									
24	日									
25	月	8:54	19.2					7.6	0.8	
26	火	8:44	18.6	39	68	8.7	<0.03	7.4	0.8	34.5
27	水	8:40	18.5					7.4	1.0	
28	木	8:42	18.9					7.5	0.6	
29	金	8:40	17.9					7.5	2.5	
30	土									
31	日									
平均		—	21.7	38	65	8.5	<0.03	7.5	1.3	34.2
最高		—	24.3	39	68	8.7	<0.03	7.6	4.2	34.8
最低		—	17.9	37	64	8.4	<0.03	7.3	0.6	33.5
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年11月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分								
1	月	8:44	18.1					7.6	0.9	
2	火	8:45	18.3	39	63	9.1	<0.03	7.6	0.9	35.3
3	水									
4	木	9:26	17.8					7.5	1.3	
5	金	8:40	17.8					7.5	1.2	
6	土									
7	日									
8	月	8:54	17.6					7.5	0.8	
9	火	8:40	17.6	39	63	8.9	<0.03	7.5	1.1	34.5
10	水	8:42	16.7					7.4	1.0	
11	木	8:41	16.7					7.4	0.9	
12	金	8:39	16.2					7.6	0.7	
13	土									
14	日									
15	月	8:39	16.1					7.4	0.7	
16	火	8:45	16.1					7.5	0.6	
17	水	8:40	16.1	39	62	9.0	<0.03	7.4	0.7	35.1
18	木	8:39	15.9					7.4	0.8	
19	金	8:38	15.7					7.4	0.8	
20	土									
21	日									
22	月	8:38	16.0					7.4	0.6	
23	火									
24	水	8:40	14.0	40	67	9.0	<0.03	7.3	1.4	35.9
25	木	8:43	14.0					7.3	0.9	
26	金	8:51	14.5					7.4	0.6	
27	土									
28	日									
29	月	8:44	12.5					7.4	0.9	
30	火	8:37	12.6					7.4	0.8	
-	-									
平均	—		16.0	39	64	9.0	<0.03	7.4	0.9	35.2
最高	—		18.3	40	67	9.1	<0.03	7.6	1.4	35.9
最低	—		12.5	39	62	8.9	<0.03	7.3	0.6	34.5
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年12月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	水	8:38	13.6	39	63	8.7	<0.03	7.4	1.4	34.8
2	木	8:38	12.0					7.3	2.2	
3	金	8:39	12.1					7.3	0.9	
4	土									
5	日									
6	月	8:49	12.1					7.3	0.7	
7	火	8:42	12.9	38	63	8.8	<0.03	7.3	0.6	33.6
8	水	8:43	12.8					7.3	2.4	
9	木	8:40	12.2					7.3	3.1	
10	金	8:40	12.2					7.2	1.1	
11	土									
12	日									
13	月	8:38	12.0					7.2	0.8	
14	火	8:36	10.8	42	68	9.5	<0.03	7.3	1.2	36.9
15	水	8:37	11.0					7.3	0.7	
16	木	8:41	11.3					7.3	0.8	
17	金	8:38	12.0					7.4	0.8	
18	土									
19	日									
20	月	8:40	9.7					7.2	1.0	
21	火	8:38	9.9	42	69	9.5	<0.03	7.2	0.8	37.6
22	水	8:41	10.3					7.2	0.7	
23	木	8:40	9.8					7.3	1.2	
24	金	8:39	10.1					7.3	1.0	
25	土									
26	日									
27	月	8:42	6.2	40	70	8.8	<0.03	7.3	2.7	35.9
28	火	8:38	6.7					7.3	1.2	
29	水									
30	木									
31	金									
平均		—	11.0	40	67	9.1	<0.03	7.3	1.3	35.8
最高		—	13.6	42	70	9.5	<0.03	7.4	3.1	37.6
最低		—	6.2	38	63	8.7	<0.03	7.2	0.6	33.6
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和4年1月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分								
1	土									
2	日									
3	月									
4	火	8:43	7.3	39	63	9.7	<0.03	7.2	1.0	34.3
5	水	8:40	6.5					7.3	1.8	
6	木	8:40	6.5					7.3	1.4	
7	金	8:39	6.6					7.3	1.8	
8	土									
9	日									
10	月									
11	火	8:44	7.5	41	70	9.2	<0.03	7.1	0.9	36.5
12	水	8:37	6.4					7.1	2.9	
13	木	8:51	6.1					7.1	2.3	
14	金	8:44	5.1					7.2	3.3	
15	土									
16	日									
17	月	8:44	6.6					7.2	0.8	
18	火	8:38	5.7	40	68	9.6	<0.03	7.2	1.5	34.9
19	水	8:39	5.5					7.2	1.6	
20	木	8:43	5.7					7.1	0.8	
21	金	9:23	5.2					7.2	1.1	
22	土									
23	日									
24	月	8:39	6.5					7.1	1.0	
25	火	8:39	5.6	42	71	11	<0.03	7.1	1.4	36.8
26	水	8:38	6.1					7.0	0.8	
27	木	8:45	7.3					7.1	1.0	
28	金	8:37	7.1					7.3	1.1	
29	土									
30	日									
31	月	8:39	7.0					7.3	1.2	
平均		—	6.3	41	68	9.9	<0.03	7.2	1.5	35.6
最高		—	7.5	42	71	11	<0.03	7.3	3.3	36.8
最低		—	5.1	39	63	9.2	<0.03	7.0	0.8	34.3
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和4年2月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	火	8:39	7.1	39	65	9.3	<0.03	7.3	1.0	35.0
2	水	8:38	7.3					7.2	0.9	
3	木	8:38	7.2					7.2	0.8	
4	金	8:38	7.3					7.2	0.8	
5	土									
6	日									
7	月	8:40	5.7					7.3	1.8	
8	火	8:38	6.1	38	63	9.5	<0.03	7.3	1.2	34.9
9	水	8:38	6.5					7.3	0.8	
10	木	8:38	7.0					7.3	1.0	
11	金									
12	土									
13	日									
14	月	8:38	7.4					7.3	1.4	
15	火	8:37	7.1	48	72	11	<0.03	7.4	1.9	42.1
16	水	8:38	7.3					7.3	0.9	
17	木	8:39	6.4					7.3	1.7	
18	金	8:38	5.7					7.3	2.6	
19	土									
20	日									
21	月	8:35	5.9					7.3	2.0	
22	火	8:39	5.5	41	72	10	<0.03	7.3	3.6	36.3
23	水									
24	木	8:39	5.5					7.3	2.3	
25	金	8:38	5.8					7.3	1.5	
26	土									
27	日									
28	月	8:39	7.2					7.3	1.5	
-	-									
-	-									
-	-									
平均		—	6.6	42	68	10	<0.03	7.3	1.5	37.1
最高		—	7.4	48	72	11	<0.03	7.4	3.6	42.1
最低		—	5.5	38	63	9.3	<0.03	7.2	0.8	34.9
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和4年3月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	火	8:44	7.6	40	68	9.8	<0.03	7.3	1.2	34.9
2	水	8:38	7.8					7.2	1.1	
3	木	8:40	7.9					7.3	1.1	
4	金	8:43	8.0					7.1	1.1	
5	土									
6	日									
7	月	8:56	7.4					7.1	2.1	
8	火	8:39	7.0	39	65	9.3	<0.03	7.2	1.0	33.8
9	水	8:41	7.3					7.3	1.5	
10	木	8:39	7.6					7.3	1.4	
11	金	8:37	7.8					7.4	1.4	
12	土									
13	日									
14	月	8:41	10.4					7.4	1.2	
15	火	8:38	10.8	42	72	8.9	<0.03	7.3	2.9	37.9
16	水	8:50	9.6					7.3	1.0	
17	木	8:42	9.9					7.1	1.1	
18	金	8:37	10.7					7.3	1.8	
19	土									
20	日									
21	月									
22	火	8:43	10.2	42	71	9.6	<0.03	7.3	1.9	36.8
23	水	8:38	9.9					7.3	2.8	
24	木	8:38	9.8					7.0	1.3	
25	金	8:38	9.8					7.0	1.2	
26	土									
27	日									
28	月	8:38	10.7					7.2	1.5	
29	火	8:39	10.4	40	70	9.4	0.10	7.2	1.4	36.0
30	水	8:36	11.0					7.3	1.3	
31	木	8:37	11.6					7.1	1.2	
平均	—		9.2	41	69	9.4	<0.03	7.2	1.5	35.9
最高	—		11.6	42	72	9.8	0.10	7.4	2.9	37.9
最低	—		7.0	39	65	8.9	<0.03	7.0	1.0	33.8
記事										