

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和7年4月

| | | 採水時刻 | 水温 | 硬度 | 蒸発残留物 | 塩素イオン | 鉄イオン | pH値 | 濁度 | 総アルカリ度 |
|----|---|-------|------|------|-------|-------|-------|-----|-----|--------|
| 日 | 曜 | 時：分 | ℃ | mg/L | mg/L | mg/L | mg/L | | 度 | mg/L |
| 1 | 火 | 8:20 | 10.2 | | | | | 7.8 | 1.1 | |
| 2 | 水 | 13:24 | 10.6 | 41 | 71 | 9.5 | <0.03 | 7.7 | 0.9 | 35.8 |
| 3 | 木 | 8:21 | 10.5 | | | | | 7.7 | 0.8 | |
| 4 | 金 | 8:24 | 10.9 | | | | | 7.9 | 0.9 | |
| 5 | 土 | 8:00 | 10.4 | | | | | 7.8 | 1.1 | |
| 6 | 日 | 8:00 | 11.1 | | | | | 7.7 | 0.8 | |
| 7 | 月 | 8:23 | 11.5 | | | | | 7.8 | 1.0 | |
| 8 | 火 | 8:35 | 11.2 | | | | | 7.7 | 0.9 | |
| 9 | 水 | 8:35 | 12.4 | 42 | 71 | 10 | <0.03 | 7.8 | 0.9 | 37.3 |
| 10 | 木 | 8:24 | 12.2 | | | | | 7.7 | 0.9 | |
| 11 | 金 | 8:24 | 12.1 | | | | | 7.6 | 0.8 | |
| 12 | 土 | 8:00 | 12.9 | | | | | 7.9 | 0.9 | |
| 13 | 日 | 8:00 | 12.7 | | | | | 7.6 | 0.8 | |
| 14 | 月 | 13:28 | 12.5 | | | | | 7.8 | 1.3 | |
| 15 | 火 | 8:44 | 12.6 | 41 | 70 | 9.4 | 0.06 | 7.7 | 0.9 | 36.4 |
| 16 | 水 | 8:36 | 12.0 | | | | | 7.7 | 0.8 | |
| 17 | 木 | 8:23 | 12.6 | | | | | 7.7 | 0.9 | |
| 18 | 金 | 8:22 | 13.6 | | | | | 7.7 | 0.7 | |
| 19 | 土 | 8:00 | 14.5 | | | | | 7.7 | 0.8 | |
| 20 | 日 | 8:00 | 15.2 | | | | | 7.7 | 0.7 | |
| 21 | 月 | 8:21 | 15.5 | 39 | 69 | 9.2 | 0.03 | 7.7 | 0.7 | 35.9 |
| 22 | 火 | 9:00 | 14.2 | | | | | 7.6 | 0.7 | |
| 23 | 水 | 8:24 | 13.6 | | | | | 7.6 | 0.5 | |
| 24 | 木 | 8:25 | 14.7 | | | | | 7.7 | 0.6 | |
| 25 | 金 | 8:24 | 13.9 | | | | | 7.7 | 0.6 | |
| 26 | 土 | 8:00 | 14.3 | | | | | 7.7 | 1.3 | |
| 27 | 日 | 8:00 | 13.6 | | | | | 7.6 | 1.2 | |
| 28 | 月 | 8:25 | 14.2 | 38 | 67 | 9.1 | <0.03 | 7.7 | 1.1 | 34.4 |
| 29 | 火 | 8:00 | 14.1 | | | | | 7.7 | 1.4 | |
| 30 | 水 | 8:24 | 14.2 | | | | | 7.7 | 1.2 | |
| - | - | | | | | | | | | |
| 平均 | | — | 12.8 | 40 | 70 | 9.4 | 0.05 | 7.7 | 0.9 | 36.0 |
| 最高 | | — | 15.5 | 42 | 71 | 10 | 0.06 | 7.9 | 1.4 | 37.3 |
| 最低 | | — | 10.2 | 38 | 67 | 9.1 | <0.03 | 7.6 | 0.5 | 34.4 |
| 記事 | | | | | | | | | | |