

水道施設管理集計表（水質検査等）

彦根浄水場 (工業用水)

令和7年4月

[illegible]

水道施設管理集計表（水質検査等）

彦根浄水場 (工業用水)

令和7年5月

[illegible]

水道施設管理集計表（水質検査等）

彦根浄水場 (工業用水)

令和7年6月

		採 水	水 温	硬 度	蒸発 残留物	塩素 イオン	鉄 イオン	pH値	濁 度	総アル カリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	日	8:00	19.2					7.8	3.6	
2	月	8:28	18.2	37	67	9.0	0.03	8.2	1.4	34.8
3	火	8:44	18.1					8.1	1.5	
4	水	8:22	18.4					8.1	1.9	
5	木	8:40	18.3					8.3	1.4	
6	金	8:22	18.7					8.4	1.7	
7	土	8:00	19.2					8.5	1.6	
8	日	8:00	19.7					8.5	1.8	
9	月	8:40	20.1					8.9	1.5	
10	火	8:28	20.9	37	65	8.9	<0.03	8.9	1.1	34.4
11	水	8:23	20.7					8.7	2.0	
12	木	8:23	20.4					7.9	6.9	
13	金	8:25	19.6					7.8	6.0	
14	土	8:00	20.0					7.9	3.8	
15	日	8:00	20.7					8.5	2.5	
16	月	8:26	20.8	38	68	8.4	0.09	8.3	2.4	36.3
17	火	8:41	22.3					8.0	2.2	
18	水	8:23	22.9					8.2	1.9	
19	木	8:24	23.2					8.5	1.7	
20	金	8:25	22.8					7.8	2.1	
21	土	8:00	23.5					8.4	1.8	
22	日	8:00	25.1					8.4	1.4	
23	月	8:24	25.6	38	63	8.7	0.04	8.4	1.1	35.0
24	火	8:39	23.9					7.8	2.4	
25	水	8:24	24.4					7.7	1.9	
26	木	8:26	24.2					7.7	2.2	
27	金	8:23	24.6					7.9	2.4	
28	土	8:00	23.4					8.2	1.7	
29	日	8:00	24.9					8.0	2.3	
30	月	8:24	25.8					8.3	1.7	
-	-									
平 均		—	21.7	38	66	8.8	0.04	8.2	2.3	35.1
最 高		—	25.8	38	68	9.0	0.09	8.9	6.9	36.3
最 低		—	18.1	37	63	8.4	<0.03	7.7	1.1	34.4
記 事										

水道施設管理集計表（水質検査等）

彦根浄水場 (工業用水)

令和7年7月

[illegible]

水道施設管理集計表（水質検査等）

彦根浄水場 (工業用水)

令和7年8月

		採水時刻	水温	硬度	蒸発 残留物	塩素 イオン	鉄 イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	金	8:23	31.3					7.8	0.9	
2	土	8:00	31.4					7.8	1.1	
3	日	8:00	30.7					7.7	1.2	
4	月	8:41	30.7	38	65	8.8	<0.03	7.8	1.2	34.8
5	火	8:23	31.5					7.8	0.9	
6	水	8:22	31.0					7.6	1.1	
7	木	8:24	30.1					7.6	1.2	
8	金	8:25	30.3					7.8	1.3	
9	土	8:00	30.0					7.7	1.2	
10	日	8:00	29.6					7.7	1.2	
11	月	8:00	29.0					7.7	1.2	
12	火	8:00	28.8					7.8	1.0	
13	水	8:00	28.8					7.8	1.0	
14	木	8:00	28.8					7.6	1.3	
15	金	8:00	29.2					7.6	1.2	
16	土	8:00	29.5					7.5	1.4	
17	日	8:00	29.9					7.7	1.2	
18	月	8:27	29.8					7.6	1.1	
19	火	8:27	29.8	41	67	9.0	0.03	7.6	1.2	34.2
20	水	8:23	30.3					7.6	1.0	
21	木	8:24	30.2					7.5	1.1	
22	金	8:24	30.6					7.7	1.0	
23	土	8:00	30.7					7.7	0.9	
24	日	8:00	30.7					7.5	1.1	
25	月	8:24	30.9	38	71	9.5	<0.03	7.6	1.0	36.9
26	火	8:24	31.3					7.7	0.9	
27	水	8:23	31.0					7.7	0.9	
28	木	8:24	30.6					7.8	0.9	
29	金	8:24	30.7					7.6	1.0	
30	土	8:00	30.7					7.8	0.9	
-	日	8:00	30.7					7.7	0.9	
平	均	—	30.3	39	68	9.1	<0.03	7.7	1.1	35.3
最	高	—	31.5	41	71	9.5	0.03	7.8	1.4	36.9
最	低	—	28.8	38	65	8.8	<0.03	7.5	0.9	34.2
記	事									

水道施設管理集計表（水質検査等）

彦根浄水場 (工業用水)

令和7年9月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	月	8:23	31.0	40	69	8.9	<0.03	7.8	1.0	35.6
2	火	8:26	31.2					7.8	0.9	
3	水	8:24	31.3					7.9	0.9	
4	木	8:23	31.0					7.5	1.1	
5	金	8:24	30.5					7.7	1.0	
6	土	8:00	30.1					7.9	1.2	
7	日	8:00	29.8					7.9	1.2	
8	月	8:25	30.3	39	70	8.9	<0.03	7.9	1.0	35.6
9	火	8:28	30.3					7.9	1.1	
10	水	8:24	30.4					7.9	1.2	
11	木	8:23	30.0					7.8	1.2	
12	金	8:25	29.6					7.9	1.1	
13	土	8:00	29.1					7.9	1.1	
14	日	8:00	29.3					7.9	1.1	
15	月	8:00	29.2					7.9	1.0	
16	火	8:26	29.4	37	72	8.9	0.04	8.0	1.2	35.4
17	水	8:25	29.4					7.8	1.2	
18	木	8:24	29.6					7.9	1.1	
19	金	8:20	28.9					8.1	1.4	
20	土	8:00	28.9					8.1	1.4	
21	日	8:00	28.4					7.9	1.4	
22	月	8:23	26.7					7.8	3.9	
23	火	8:00	27.0					8.0	1.6	
24	水	8:24	26.9	39	74	9.4	0.19	8.1	1.6	34.3
25	木	8:28	26.6					8.0	1.7	
26	金	8:24	26.4					8.0	1.7	
27	土	8:00	26.2					8.1	2.5	
28	日	8:00	25.5					8.3	2.1	
29	月	8:27	25.9	37	72	9.3	0.05	8.1	2.0	37.0
30	火	8:24	25.0					8.0	2.0	
-	-									
平均		—	28.8	38	71	9.1	0.06	7.9	1.4	35.6
最高		—	31.3	40	74	9.4	0.19	8.3	3.9	37.0
最低		—	25.0	37	69	8.9	<0.03	7.5	0.9	34.3
記事										