

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和8年4月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	水	8:19	12.4					7.8	2.9	
2	木	8:19	11.9					7.7	3.7	
3	金	8:46	11.6					7.8	2.8	
4	土	8:00	11.7					7.7	2.9	
5	日	8:00	12.0					7.7	2.8	
6	月	8:19	11.6	38	69	9.2	<0.03	7.6	2.7	35.3
7	火	8:44	12.3					7.8	2.7	
8	水	8:20	11.0					7.7	3.6	
9	木	8:20	11.2					7.8	3.0	
10	金	8:19	12.3					7.7	2.8	
11	土	8:00	12.8					7.7	3.0	
12	日	8:00	13.0					7.7	3.0	
13	月	8:23	13.1					7.7	2.8	
14	火	8:24	13.4	41	71	9.5	0.04	7.7	2.9	37.1
15	水	8:52	14.1					7.7	2.8	
16	木	8:20	14.1					7.8	3.1	
17	金	8:20	13.7					7.8	2.9	
18	土	8:00	14.0					7.8	2.8	
19	日	8:00	14.7					7.8	2.9	
20	月	8:19	14.8	38	69	9.1	<0.03	7.9	2.9	35.9
21	火	8:27	14.6					7.9	3.1	
22	水	8:20	14.6					7.8	2.8	
23	木	8:18	14.7					7.8	2.7	
24	金	8:20	14.8					7.8	2.7	
25	土	8:00	14.8					7.8	3.4	
26	日	8:00	15.1					7.7	2.8	
27	月	8:20	15.2	40	66	9.2	0.03	7.7	2.8	36.4
28	火	8:25	15.5					7.7	2.8	
29	水	8:00	16.3					7.7	3.7	
30	木	8:24	15.3					7.7	3.2	
-	-									
平均	—		13.6	39.3	68.8	9.3	<0.03	7.8	3.0	36.2
最高	—		16.3	41	71	9.5	0.04	7.9	3.7	37.1
最低	—		11.0	38	66	9.1	<0.03	7.6	2.7	35.3
記事										